

■ NATURE OF EVENTS CLASSIFIED ON INES

INES enables ASN to classify all events occurring in civil basic nuclear installations (BNIs) and during transport of radioactive materials according to their significance. Since 1 July 2008, INES can also be used by the 60 member countries of IAEA for the classification of radiation protection events related to the use of radioactive sources in medical (excluding patients), industrial and research facilities. The application of INES to BNIs is based on three classification criteria (columns 2, 3 and 4 of the table overleaf):

- **the consequences off the site**, assessed in terms of releases of radioactivity that can affect people and the environment;
 - **the consequences on the site**, potentially affecting workers and installations;
 - **deterioration of the facility's defence in depth**, consisting of consecutive barriers (safety systems, procedures, technical or administrative controls, etc.) designed to prevent accidents.
- The classification criteria for radiation protection events are given in the table overleaf.

■ EXAMPLES OF EVENTS CLASSIFIED ACCORDING TO INES

Level 0. In France: several hundred events are classified at level 0 each year. They concern deviations from normal facility operations, normal use of radioactive sources or normal transport operations. They have no safety significance.

Level 1. In France: about a hundred events are classified at level 1 each year. This concerns anomalies, deviations from the facility's authorised operating conditions, abnormal use of radioactive sources or abnormal transport operations, owing to equipment failure, human error or inadequate application of procedures.

Level 2. In France: 2006: blockage of a water intake by the large-scale arrival of plant debris at the Cruas NPP. Under-estimation of plutonium deposits in the gloveboxes of the plutonium technology facility (ATPu). Accidental irradiation of a worker from the HORUS company during a gamma radiography weld inspection. Safety-criticality limit exceeded in the MELOX facility. 2006: improper use of a MOX fuel fabrication scrap crusher at the ATPu on the Cadarache site, resulting from the application of inappropriate procedures and instructions without official validation. 2005: anomaly concerning certain safety system pumps of EDF 900 MWe reactors, potentially leading, under certain accident conditions, to loss of the cooling water recirculation function.

Level 3. In France: 2008: irradiation by a Cobalt 60 source of a worker in an irradiation bunker on the ONERA site in Toulouse. 2002: incident classified by the competent Swedish authority during transport by the carrier Federal Express (FedEx) between Sweden and the United States via Paris Roissy airport of a package showing on arrival a dose rate above the regulatory limit. 1981: fire in a storage silo at La Hague. **In other countries:** 2008: abnormal release of iodine 131 by the stack of the Institut des radioéléments (IRE – national radioelements institute) building at Fleurus (Belgium) during a transfer of liquid effluents between tanks. 2005: detection of a radioactive leak in piping in the Thorp fuel reprocessing plant at Sellafield (United Kingdom). 2002: discovery in the reactor of the Davis Besse plant (United States) of a cavity in the vessel closure head due to metal corrosion by boric acid.

Level 4. In France: 1980: damage to the core of reactor A1 at Saint-Laurent-des-Eaux. **Abroad:** 2006: irradiation by a Cobalt 60 source of a worker in a sterilisation facility using ionising radiations (Belgium). 1999: criticality accident in a fuel fabrication plant at Tokai-Mura (Japan), with acute irradiation of three workers, two of whom died. 1973: release of radioactive materials following an exothermic reaction in a reprocessing tank at the Windscale plant (United Kingdom).

Level 5. In France: none. **In other countries:** 1979: partial reactor core meltdown at Three Mile Island NPP (United States).

Level 6. In France: none. **In other countries:** 1957: explosion of a tank containing radioactive materials at the Kyshtym reprocessing plant (USSR).

Level 7. In France: none. **In other countries:** 1986: explosion of the reactor 4 at Chernobyl NPP (Ukraine).

■ USE OF INES IN FRANCE

All events significant for nuclear safety must be notified to ASN by the licensees within 48 hours, with a proposed INES classification.

ASN retains sole responsibility for the final classification decision.

The use of INES enables ASN to identify the events and incidents of sufficient importance for it to issue a communication.

• **Events classified at level 0** are not reported in incident notices, unless they are of particular interest.

• **All events classified at level 1** are reported in incident notices published on the ASN website www.asn.fr.

• **Events classified at level 2** and above are also reported by press releases and notified to the IAEA.

International transport events concerning a foreign country are also notified to IAEA as of level 1 and as of level 0 if they involve the loss of a radioactive source. ■

INES CLASSIFICATION OF RADIATION PROTECTION EVENTS

In France, the application guide for the new INES allowing classification of radiation protection events (not affecting patients) involving radioactive sources and radioactive material transport operations, is currently being produced. Radiotherapy events affecting patients are classified on the ASN-SFRO scale issued by ASN in July 2008.

EVENT	NUMBER OF PERSONS EXPOSED AND FINAL CLASSIFICATION		
	MINIMUM CLASSIFICATION	NUMBER OF PERSONS	FINAL CLASSIFICATION*
Death or lethal dose received		> 10	6
	4	> 1	5
		1	4
Deterministic effect or potential deterministic effect given the received dose		> 10	5
	3	> 1	4
		1	3
Exposure higher than 1 Sv or 1 Gy		> 100	6
	4	> 10	5
		≤ 10	4
Exposure higher than 100 mSv		> 100	5
	3	> 10	4
		≤ 10	3
Worker exposure to a dose above the annual regulatory limit or exposure of a member of the public to a dose greater than 10 mSv		> 100	4
	2	> 10	3
		≤ 10	2
Worker exposure to a dose greater than one quarter of the annual regulatory limit or exposure of a member of the public to a dose above the annual dose limit		> 100	3
	1**	> 10	2
		≤ 10	1

* The highest classification is selected.

** When a dose limit is exceeded as a result of accumulated exposure over a given period of time, ASN systematically assigns a level 1 classification because of inadequate safety culture.